RAILINGS? OK

EXIT CAP. 105 OCC.

STAIR 101

LIBRARY 100 OCC. 80

A.V. CLOSET 102

EXIT CAP 105 OCC

2 HR. RATED NEW

ON 115A EXIT CAP 105 OCC

1 HR. RATED EXISTING

STAIR 103

5 A10.4

NEW / EXISTING

USE GROUP: EDUCATIONAL
OCCUP.= 80
CC CONST. NON COMB.
UNPROTECTED ALLOW
BLDG AREA = 11,400
2 STORIES 30
ACADEMIC ADDITION = 8600
2 STAIRS - 2½ HR.
2566 OVERCORE COMP.

COMPUTER RM. 104 OCC. 5

3RD GRADE 105 OCC. 40

1 HR. RATED EXISTING

ART 106 OCC. 41

10½" VIF

CORRIDOR 124

3 RD GRADE 107 OCC. 40

NEW FLASHING & COUNTER FLASHING

NEW FIBERGLASS SHINGLED ROOF SEE DWG. 4/A-103

TEACH R/M. 108 OCC. 4

C.O. 108A

C.O. 109A

CUSTODIAN 109 OCC. 1

STORAGE 110

EXIST. 3 SINK

EXISTING SCREENED IN AREAWAY

NEW ADDITION

KITCHEN 111 OCC. 6

EXIST. RANGE HOOD

7 A10.4

EXIT CAP 105

EXIT CAP 105

STORAGE 116

1 HR. RATED EXISTING

NEW OPENING

1 HR. RATED EXISTING

CAFETERIA 114 OCC. 160

MUSIC 117 OCC. 41

EXISTING WIRE GLASS WINDOWS & METAL FRAME

1 HR. RATED NEW

EXIT CAP 105

1 HR. RATED EXISTING

EXIT CAP 105

JAN. BOYS 119 19

NURSE 132 OCC. 3

JAN 131

GIRLS 118

STAIR 115

EXIT CAP 330

EXIT CAP 330

JAN 130

STORAGE 133

TOILET 135

20 LKR 134

CLASSRM. 3RD 139 OCC. 42

CLASSRM. 2ND 140 OCC. 42

CLASSRM. 1ST 143 OCC. 42

CLASSRM. 1ST 144 OCC. 42

CORRIDOR 147

CLOSET 148

EXIT CAP 330

EXIST'G DISPLAY CASE

BOOKS 149

CLASSRM. KINDERG. 150 OCC. 50

1 HR. RATED EXISTING

GYM/AUDITORIUM 120

OCC. AS A GYM = 247
OCC. AS AUD. = 1075

EXIT CAP 330

EXIST. DRAIN

1 HR. RATED EXISTING

CORRIDOR 140

10'-0" V.I.F.

1 HR. RATED EXISTING

CLASSRM. KINDERG. 151 OCC. 50

BOOKS 152

EXIT CAP 330

CLOSET 153

193 STORAGE 121

JAN 136

GIRLS 137

OFF. CE 124 OCC. 4

PR. NO. 47 OCC. 6

OR E.D. 118 OCC. 30

CLASSRM 2 ND 138 OCC. 42

CLASSRM 2 ND 141 OCC. 42

1 ST 142 OCC. 42

1 ST 145 OCC. 42

GUIDANCE S.W. 11 OCC. 4

EXIT CAP 105

STAIR 121B

STAIR 121A

EXIT CAP 330

EXIT CAP 105

EXIT CAP 330

108 FT TRAVEL DISTANCE

DOOR SIZE NOT SHOWN TO VERIFY CAPACITY - IS AS MULLION SUBTRACTED?

EXIST. HATCH ABOVE

E. D. H/ REMEDIAL MATH 122 OCC. 10

STORAGE 121

2 A15.3 EXISTING LOFT ABOVE GUIDANCE
SCALE: ¼" = 1'-0"

1 A15.3 UPPER LEVEL
1/16" = 1'-0"

N

GENERAL INFO.

1. BUILDING USE GROUP IS E EDUCATIONAL
2. EXISTING BUILDING IS UNSPRINKLERED. ADDITIONS ARE UNSPRINKLERED.
3. OCCUPANT LOADS = 20 SF/OCCUPANT IN CLASSROOMS
   15 SF/OCCUPANT IN ASSEMBLY AREAS (CONCENTRATED IN AUDITORIUM).
   15 SF/OCCUPANT IN ASSEMBLY AREAS (NON CONCENTRATED IN CAFETERIA).
   100 SF/OCCUPANT IN OFFICE AREA.
   50 SF/OCCUPANT IN LIBRARY AREA
4. TRAVEL DISTANCE TO AN EXIT SHALL NOT EXCEED 150'-0" FROM ANY POINT IN THE BUILDING. BUILDING COMPLIES
5. SMOKE DETECTION SYSTEM EXISTS WITHIN EXISTING BUILDING. SMOKE DETECTION SYSTEM IS EXTENDED AND IMPROVED IN THE NEW ADDITIONS
6. TOTAL OCCUPANCY NOT INCLUDING CAFETERIA, GYM/AUD AT UPPER LEVEL = 677
   EXIT EGRESS CAPACITY AT UPPER LEVEL = 1215 (NOT INC. CAFET/GYM)

LEGEND

- ● 1 HOUR FIRE SEPARATION WALL AND/OR SMOKE BARRIER.
- ●● 2 HOUR FIRE WALL

RECEIVED

STATE PROJECT # 034-89-115 EA

Antinozzi Associates Architects
4021 Main Street
Stratford, Connecticut

DANBURY SCHOOLS REORGANIZATION
CITY OF DANBURY
PARK AVENUE ELEMENTARY
DANBURY, CONNECTICUT

FLOOR PLAN
UPPER LEVEL

CHECKED BY | SCALE 1/16" = 1'-0" | DATE 1-24-91 | JOB NO. 90-1.12

A15.3

© ANTINOZZI ASSOCIATES P.C. '91